TOWN OF WOODLOCH

Public Water Supply ID: TX1700112

Consumer Confidence Report

2025 CCR

Scanned with CamScanner

Annual Drinking Water Quality Report

TOWN OF WOODLOCH

Public Water System ID: TX1700112

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. Opportunities for public participation in decisions that may affect the quality of the water can be obtained by attending City Council meetings that occur the third Monday of every month held at the Town of Woodloch City Hall at 2620 South Woodloch Conroe Texas 77385. Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (936) 321-3700.

For more information regarding this report, contact:

Name: Town of Woodloch City Secretary

Phone: 936-321-3700

Sources of Drinking Water

TOWN OF WOODLOCH is Ground water pumped from the Evangeline Aquifer in Montgomery County Texas.

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
1 - PLUGGED	2625 N WOODLOCH	Ground water		
2 - PLUGGED	2625 N WOODLOCH	Ground water		
3 - PLUGGED	2631 N WOODLOCH	Ground water		
4 - PLUGGED	STP	Ground water		
5 - PLUGGED	2620 N WOODLOCH	Ground water		
6 - 16065 NEEDHAM DR / PT	16065 NEEDHAM DR	Ground water	Active	Water Plant 1
7 - 16065 NEEDHAM RD / GST	16065 NEEDHAM RD	Ground water	Active	Water Plant 1

Scanned with CamScanner

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

As part of the U.S. Environmental Protection Agency's (EPA) revised Lead and Copper Rule, Town of Woodloch has completed a full inventory of service lines within our water distribution system, including both the public (utility-owned) and private (customer-owned) portions of each service connection. Based on a thorough review of historical records, customer outreach, and material verification, no lead or galvanized service lines requiring replacement were identified on either the public or private side of our system, nor any unknown service lines were identified. All service lines are confirmed to be made of non-lead materials such as copper, plastic, or other EPA-approved materials. Although no lead service lines were found, we remain proactive in maintaining accurate records and ensuring ongoing compliance with all regulatory requirements. If you have questions about your service line material, would like to view our inventory, or are interested in voluntary water testing, please contact us at 936-321-3700

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.
Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. TOWN OF WOODLOCH is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap,

Scanned with CamScanner

taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact TOWN OF WOODLOCH at 936-321-3700. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at https://www.epa.gov/safewater/lead.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.
RAA: Running Annual Average.
LRAA: Locational Running Annual Average.
mrem: millirems per year (a measure of radiation absorbed by the body).
ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.
picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.
na: not applicable.

Scanned with CamScanner

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Free Chlorine Residual	2025	1.68	PPM	.48-7.70	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2025	0.124	0.00404 - 0.394	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2025	0.781	0 - 22.4	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	10908 RIVER OAK, WOODLOCH	2025	0	0	ppb	60	0	By-product of drinking water disinfection
TTHM	10908 RIVER OAK, WOODLOCH	2025	0	0	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	2/1/2023	0.18	0.18	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE	1/11/2024	0.13	0.13	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL	2/1/2023	0.0038	0.0038	MG/L	0	0.1	
NITRATE-NITRITE	9/7/2023	0.05	0.05	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source

Scanned with CamScanner

COMBINED RADIUM (-226 & -228)	1/15/2020	1.5	1.5	pCi/L	5	0	Erosion of natural deposits

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
7/1/2025	CONSUMER CONFIDENCE RULE	CCR REPORT	Failed to deliver Consumer Confidence Report to the state or consumers on time

Additional Required Health Effects Language:

Infants and children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4761).

There are no additional required health effects violation notices.

Scanned with CamScanner

Public Water System
NAME: Town Of Woodloch
ID: 1700112

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Lead Treatment Technique Requirements Not Met

Our water system recently violated a drinking water requirement. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

Failure to meet minimum treatment requirements for lead has the potential to increase your exposure to lead. We did not complete the following requirement(s):

Requirement(s) not met: Did not submit the LSLI on time to TCEQ

Period(s) of Non-Compliance: October 2024

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

What should I do?

There is nothing you need to do at this time. You may continue to drink the water. We will notify you within 24 hours if a situation arises where the water is no longer safe to drink.

What is being done?

We completed our Lead Service Line Inventory on 4/22/2025

Expected completion date for the corrective action: 4/22/2025

For more information, please contact:

PWS Contact Name: Jason Sessum

Phone: 936-321-3700 **Email: citysecretary@woodlochtx.org**

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date distributed: 5/22/2025

Scanned with CamScanner

LEAD & COPPER RULE MONITORING AND REPORTING VIOLATION
MANDATORY LANGUAGE - TIER III

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

TOWN OF WOODLOCH (PWS 1700112) has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During (52) 3YR2024, **2017,** *we did not monitor or test for LCR and therefore cannot be sure of the quality of your drinking water during that time.*

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for [these contaminants], how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples were [or will be] taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were or will be taken
LCR SAMPLE TAP 2017	*10 / 6 month*	0	*JUN 1, 2017 - SEPT 30, 2017*	*10/12/2018*
LCR SAMPLE TAP 3YR2024	*5 / triennially*	0	*JUN 1, 2024 - SEPT 30, 2024*	*06/05/2025*

What is being done?
We completed complete sets of sample tap samples as requested by TCEQ and we returned to compliance as of 10/12/2018 and 06/05/2025.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

We are working to correct the problem. For more information, please contact

Name of Water System Official: _Jason Sessum_____

Area code + Phone number: _936-321-3700_____ Date Distributed: __5/22/2025_____

This notice is being sent to you by **TOWN OF WOODLOCH**
Public Water System Number: **TX1700112.**

Scanned with CamScanner